

UNIVERSIDADE FEDERAL DO RIO GRANDE DO SUL

INSTITUTO DE PESQUISAS HIDRÁULICAS

Internal Report

**Detailing the performance of hydro PV hybrid systems  
with incomplete energetic complementarity:  
case studies with  $\kappa = 0.90$  and  $\kappa_t = 0.90$**

Alexandre Beluco

Porto Alegre, February 27, 2014.

## CONTENTS

Apresentação. ....	11
<b>1</b> Effects of different proportions between energy available for consumption and energy demanded by loads ( $p_{dd}$ ) on the performance of a system with $\kappa_t=1,00$ , $\kappa_e=1,00$ [ $p_{sh}=1,00$ ], $\kappa_a=1,00$ [ $p_{Mm}=1,00$ , $df=1,1496$ , $dh=df$ ], $\kappa=1,00$ , with $p_{he\ máx}=p_{c\ máx}$ , with bank of batteries with capacity for 2 days, with discharge until 40% and charge until 100% of maximum capacity, without water reservoir and with constant load demand profile. Proportions: (1) $p_{dd}=0,8000$ , $a_f=19,69$ , (2) $p_{dd}=0,9000$ , $a_f=22,15$ , (3) $p_{dd}=0,9500$ , $a_f=23,38$ , (4) $p_{dd}=0,9800$ , $a_f=24,12$ and (5) $p_{dd}=0,9850$ , $a_f=24,25$ . Conventions: SOC: state of charge of the batteries, $p_H$ : power made available by the hydro generator set, $p_{F\ máx\ d}$ : maximum daily power made available by the PV generator set, $p_{cA}$ : power delivered to the loads. ....	12
<b>2</b> Effects of different dimensions of bank of batteries on the performance of a system with $p_{dd}=1,00$ , $\kappa_t=1,00$ , $\kappa_e=1,00$ [ $p_{sh}=1,00$ ], $\kappa_a=1,00$ [ $p_{Mm}=1,00$ , $df=1,1496$ , $dh=df$ ], $\kappa=1,00$ , with $p_{he\ máx}=p_{c\ máx}$ and $a_f=24,61$ , without water reservoir and with constant load demand profile. Banks of batteries with capacity for (1) 0,500 day, (2) 0,550 day, (3) 0,600 day, (4) 0,625 day and (5) 0,650 day, with discharge until 40% and charge until 100% of maximum capacity. Conventions: SOC: state of charge of the batteries, $p_H$ : power made available by the hydro generator set, $p_{F\ máx\ d}$ : maximum daily power made available by the PV generator set, $p_{cA}$ : power delivered to the loads. ....	16
References. ....	89

## PRESENTATION

This report presents the results of computational simulation of hybrid systems based on PV and hydroelectric energy, as part of the doctoral thesis of the first author. The results were also used to build some graphics used in papers submitted to the journal Renewable Energy, Elsevier.




FIGURE 1. Effects of different proportions between energy available for consumption and energy demanded by loads ( $p_{dd}$ ) on the performance of a system with  $\kappa_t=1,00$ ,  $\kappa_e=1,00$  [ $p_{sh}=1,00$ ],  $\kappa_a=1,00$  [ $p_{Mm}=1,00$ ,  $df=1,1496$ ,  $dh=df$ ],  $\kappa=1,00$ , with  $p_{he\ máx}=p_{c\ máx}$ , with bank of batteries with capacity for 2 days, with discharge until 40% and charge until 100% of maximum capacity, without water reservoir and with constant load demand profile. Proportions: (1)  $p_{dd}=0,8000$ ,  $a_f=19,69$ , (2)  $p_{dd}=0,9000$ ,  $a_f=22,15$ , (3)  $p_{dd}=0,9500$ ,  $a_f=23,38$ , (4)  $p_{dd}=0,9800$ ,  $a_f=24,12$  and (5)  $p_{dd}=0,9850$ ,  $a_f=24,25$ . Conventions: SOC: state of charge of the batteries,  $p_H$ : power made available by the hydro generator set,  $p_{F\ máx\ d}$ : maximum daily power made available by the PV generator set,  $p_{cA}$ : power delivered to the loads.




FIGURE 2. Effects of different dimensions of bank of batteries on the performance of a system with  $p_{dd}=1,00$ ,  $\kappa_t=1,00$ ,  $\kappa_e=1,00$  [ $p_{sh}=1,00$ ],  $\kappa_a=1,00$  [ $p_{Mm}=1,00$ ,  $df=1,1496$ ,  $dh=df$ ],  $\kappa=1,00$ , with  $p_{he\ máx}=p_{c\ máx}$  and  $a_f=24,61$ , without water reservoir and with constant load demand profile. Banks of batteries with capacity for (1) 0,500 day, (2) 0,550 day, (3) 0,600 day, (4) 0,625 day and (5) 0,650 day, with discharge until 40% and charge until 100% of maximum capacity. Conventions: SOC: state of charge of the batteries,  $p_H$ : power made available by the hydro generator set,  $p_F^{máx d}$ : maximum daily power made available by the PV generator set,  $p_{cA}$ : power delivered to the loads.

**REFERENCES**

- Beluco, A. (2001) Bases para uma metodologia de dimensionamento de aproveitamentos híbridos baseados em energias hidrelétrica e fotovoltaica. Universidade Federal do Rio Grande do Sul, Programa de Pós Graduação em Engenharia Mecânica, Doctoral thesis, 202p.
- Beluco, A. (2013) Detailing the effects of complementarity between the amplitudes on the performance of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report.
- Beluco, A. (2013) Detailing the effects of complementarity of energy on the performance of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report.
- Beluco, A. (2013) Detailing the effects of complementarity in time on the performance of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report.
- Beluco, A. (2013) Detailing the effects of the size of battery bank on the performance of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report.
- Beluco, A. (2013) Detailing the effects of the use of water storage on the performance of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report.
- Beluco, A.; Souza, P.K.; Krenzinger, A. (2008) PV hydro hybrid systems. IEEE Latin America Transactions, v.6, p.626-631.
- Beluco, A.; Souza, P.K.; Krenzinger, A. (2010) Computational simulation of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report, 21p.
- Beluco, A.; Souza, P.K.; Krenzinger, A. (2010) Results of computational simulation of hydro PV hybrid systems based on complementary energy resources. Universidade Federal do Rio Grande do Sul, instituto de Pesquisas Hidráulicas, Internal Report, 90p.